

Generating Set Functional Test Report
In accordance with ISO 8528 - 6 2005

PLANT NUMBER: E9656 CE: No

RATED OUTPUT	KVA	<u>140</u>	RATING CLASSIFICATION	<u>PRP</u>	
	KW	<u>112</u>			
	PHASE	<u>3</u>			
	VOLTS	<u>415/240</u>		PERFORMANCE CLASS	<u>G1</u>
	AMPS	<u>195</u>		(AS DEFINED BY ISO 8528-1)	
	HZ	<u>50</u>			
	RPM	<u>1500</u>			
GOVERNOR TYPE	<u>Electronic</u>		COOLING METHOD	<u>WATERCOOLED</u>	

ENGINE MAKE	<u>Perkins</u>	BUILD NUMBER	<u>YDS1440</u>
ENGINE MODEL	<u>1006 TAG</u>	SERIAL NUMBER	<u>UA11424T</u>
ALTERNATOR MAKE	<u>Mecc Alte</u>		
ALTERNATOR MODEL	<u>ECP34-2L/4</u>	SERIAL NUMBER	<u>A1083940</u>
CONTROL PANEL(S)	<u>Amstart</u>	SERIAL NUMBER(S)	
SWITCHGEAR		SERIAL NUMBER(S)	

LOAD TEST RESULTS (AT UNITY POWER FACTOR)

LOAD TYPE	LOAD %	HZ	VOLTS	AMPS	KW	ENGINE TEMP DEG C	OIL TEMP DEG C	OIL PRESS BAR
load acceptance	<u>65%</u>	<u>50.0</u>	<u>415</u>	<u>101</u>	<u>73</u>	<u>-</u>	<u>-</u>	<u>5.0</u>
standby/ prime+10%	<u>110%</u>	<u>50.0</u>	<u>415</u>	<u>172</u>	<u>123</u>	<u>83</u>	<u>-</u>	<u>4.2</u>

GENERATING SET ENCLOSURE MECHANICAL PROTECTION IP
 AVERAGE SOUND PRESSURE LEVEL (DBA AT 1 M)
 (UNITS WITH ACOUSTIC CANOPIES ONLY & MEASURED UNDER TEST BAY CONDITIONS AT 75% LOAD
 IN ACCORDANCE WITH ISO8528-10)

AMBIENT TEST CONDITIONS		FUEL/OIL USED	
ALTITUDE (M)	<u>Sea Level</u>	FUEL SPEC	<u>BS2869A2</u>
BAROMETRIC PRESSURE (kpa)	<u>101.7</u>	DENSITY	<u>0.84 kg/l</u>
TEMPERATURE (Deg c)	<u>17</u>	CALORIFIC VALUE	<u>42.5 MJ/kg</u>
HUMIDITY (%)	<u>72</u>	LUB OIL SPEC	<u>Multigrade</u>

WIRING DIAGRAMS:

ENGINE	<u>09-160900</u>	CONTROL PANEL(S)	<u>Am3-986F</u>
--------	------------------	------------------	-----------------

TESTED BY

H. Wal

DATE 08/07/2010