

Generating Set Functional Test Report

In accordance with ISO 8528 - 6 2005

PLANT NUMBER: E9666 CE: No

RATED OUTPUT	KVA	<u>93</u>	RATING CLASSIFICATION	<u>PNP</u>
	KW	<u>76.4</u>		
	PHASE	<u>3</u>		
	VOLTS	<u>415/240</u>		PERFORMANCE CLASS G1
	AMPS	<u>129</u>		
	HZ	<u>50</u>		
RPM	<u>1500</u>			
GOVERNOR TYPE			COOLING METHOD	<u>WATERCOOLED</u>

ENGINE MAKE	<u>PERKINS</u>	BUILD NUMBER	<u>YBS1438</u>
ENGINE MODEL	<u>LOD6811A</u>	SERIAL NUMBER	<u>U908897T</u>
ALTERNATOR MAKE	<u>STAMFORD</u>		
ALTERNATOR MODEL	<u>UC2 274C</u>	SERIAL NUMBER	<u>02 9506/006</u>
CONTROL PANEL(S)	<u>MANUAL START</u>	SERIAL NUMBER(S)	
SWITCHGEAR		SERIAL NUMBER(S)	

LOAD TEST RESULTS (AT UNITY POWER FACTOR)

LOAD TYPE	LOAD %	HZ	VOLTS	AMPS	KW	ENGINE TEMP	OIL TEMP	OIL PRESS
						DEG C	DEG C	BAR
load acceptance	<u>75</u>	<u>50.9</u>	<u>415</u>	<u>78</u>	<u>56</u>	<u>-</u>	<u>-</u>	<u>4.8</u>
standby/ prime+10%	110%	<u>50.0</u>	<u>415</u>	<u>114</u>	<u>82</u>	<u>82</u>	<u>-</u>	<u>4.1</u>

GENERATING SET ENCLOSURE MECHANICAL PROTECTION

IP

AVERAGE SOUND PRESSURE LEVEL (DBA AT 1 M)

—

(UNITS WITH ACOUSTIC CANOPIES ONLY & MEASURED UNDER TEST BAY CONDITIONS AT 75% LOAD IN ACCORDANCE WITH ISO8528-10)

AMBIENT TEST CONDITIONS		FUEL/OIL USED	
ALTITUDE (M)	<u>Sea Level</u>	FUEL SPEC	<u>BS2869A2</u>
BAROMETRIC PRESSURE (kpa)	<u>102.0</u>	DENSITY	<u>0.84 kg/l</u>
TEMPERATURE (Deg c)	<u>18</u>	CALORIFIC VALUE	<u>42.5 MJ/kg</u>
HUMIDITY (%)	<u>83</u>	LUB OIL SPEC	<u>Multigrade</u>

WIRING DIAGRAMS:

ENGINE	<u>08-152300</u>	CONTROL PANEL(S)	<u>10-170800</u>
--------	------------------	------------------	------------------

TESTED BY

I. JOHNSON

DATE

19/07/2010