

**Generating Set Functional Test Report**  
In accordance with ISO 8528 - 6 2005

PLANT NUMBER:   E9718   CE:   NO  

RATED OUTPUT	KVA	<u>30</u>	RATING CLASSIFICATION	<u>Prp</u>	
	KW	<u>24</u>			
	PHASE	<u>3</u>			
	VOLTS	<u>400/230</u>		PERFORMANCE CLASS	<u>G1</u>
	AMPS	<u>43</u>		(AS DEFINED BY ISO 8528-1)	
	HZ	<u>50</u>			
	RPM	<u>1500</u>			
GOVERNOR TYPE	<u>Mechanical</u>	COOLING METHOD	<u>Watercooled</u>		

ENGINE MAKE	<u>Pennins</u>	BUILD NUMBER	<u>DJS1434</u>
ENGINE MODEL	<u>1103A - 33G</u>	SERIAL NUMBER	<u>U2427701</u>
ALTERNATOR MAKE	<u>MCC-ALTE</u>		
ALTERNATOR MODEL	<u>B1028 - VL4</u>	SERIAL NUMBER	<u>001426368</u>
CONTROL PANEL(S)	<u>AUTO START</u>	SERIAL NUMBER(S)	
SWITCHGEAR	<u>—</u>	SERIAL NUMBER(S)	

**LOAD TEST RESULTS (AT UNITY POWER FACTOR)**

LOAD TYPE	LOAD %	HZ	VOLTS	AMPS	KW	ENGINE TEMP DEG C	OIL TEMP DEG C	OIL PRESS BAR
load acceptance	<u>110</u>	<u>50.4</u>	<u>400</u>	<u>31</u>	<u>21.6</u>	<u>—</u>	<u>—</u>	<u>4.4</u>
standby/prime+10%	<u>110%</u>	<u>50.0</u>	<u>400</u>	<u>38</u>	<u>26.4</u>	<u>82</u>	<u>—</u>	<u>4.2</u>

GENERATING SET ENCLOSURE MECHANICAL PROTECTION   IP    
 AVERAGE SOUND PRESSURE LEVEL (DBA AT 1 M)   —    
 (UNITS WITH ACOUSTIC CANOPIES ONLY & MEASURED UNDER TEST BAY CONDITIONS AT 75% LOAD IN ACCORDANCE WITH ISO8528-10)

AMBIENT TEST CONDITIONS		FUEL/OIL USED	
ALTITUDE (M)	<u>Sea Level</u>	FUEL SPEC	<u>BS2869A2</u>
BAROMETRIC PRESSURE (kpa)	<u>101.3</u>	DENSITY	<u>0.84 kg/l</u>
TEMPERATURE (Deg c)	<u>21</u>	CALORIFIC VALUE	<u>42.5 MJ/kg</u>
HUMIDITY (%)	<u>53</u>	LUB OIL SPEC	<u>Multigrade</u>

**WIRING DIAGRAMS:**

ENGINE	<u>06-130700</u>	CONTROL PANEL(S)	<u>AMB-986F</u>
--------	------------------	------------------	-----------------

TESTED BY   I. JOHNSON  

DATE   29/07/2010