

Generating Set Functional Test Report

In accordance with ISO 8528 - 6 2005

PLANT NUMBER:

EG719

CE:

NO

RATED OUTPUT	KVA	<u>60</u>	RATING CLASSIFICATION	<u>POP</u>	
	KW	<u>48</u>			
	PHASE	<u>3</u>			
	VOLTS	<u>400/230</u>		PERFORMANCE CLASS	<u>G1</u>
	AMPS	<u>87</u>			
	HZ	<u>50</u>			
	RPM	<u>1500</u>			
GOVERNOR TYPE			<u>MECHANICAL</u>	COOLING METHOD	<u>WATERCOOLED</u>

ENGINE MAKE	<u>PENIXINS</u>	BUILD NUMBER	<u>DKS1436</u>
ENGINE MODEL	<u>11031A-3322</u>	SERIAL NUMBER	<u>U243929U</u>
ALTERNATOR MAKE	<u>WELL-ALTE</u>		
ALTERNATOR MODEL	<u>ECO32-2L4</u>	SERIAL NUMBER	<u>A1083018</u>
CONTROL PANEL(S)	<u>AUTODIANT</u>	SERIAL NUMBER(S)	
SWITCHGEAR	<u>—</u>	SERIAL NUMBER(S)	

LOAD TEST RESULTS (AT UNITY POWER FACTOR)

LOAD TYPE	LOAD %	HZ	VOLTS	AMPS	KW	ENGINE TEMP DEG C	OIL TEMP DEG C	OIL PRESS BAR
load acceptance	<u>90</u>	<u>50.6</u>	<u>400</u>	<u>63</u>	<u>43</u>	<u>—</u>	<u>—</u>	<u>4.9</u>
standby/ prime+10%	<u>110%</u>	<u>50.0</u>	<u>400</u>	<u>77</u>	<u>53</u>	<u>85</u>	<u>—</u>	<u>3.7</u>

GENERATING SET ENCLOSURE MECHANICAL PROTECTION

IP

AVERAGE SOUND PRESSURE LEVEL (DBA AT 1 M)

—

(UNITS WITH ACOUSTIC CANOPIES ONLY & MEASURED UNDER TEST BAY CONDITIONS AT 75% LOAD IN ACCORDANCE WITH ISO8528-10)

AMBIENT TEST CONDITIONS		FUEL/OIL USED	
ALTITUDE (M)	<u>Sea Level</u>	FUEL SPEC	<u>BS2869A2</u>
BAROMETRIC PRESSURE (kpa)	<u>100.2</u>	DENSITY	<u>0.84 kg/l</u>
TEMPERATURE (Deg c)	<u>14</u>	CALORIFIC VALUE	<u>42.5 MJ/kg</u>
HUMIDITY (%)	<u>77</u>	LUB OIL SPEC	<u>Multigrade</u>

WIRING DIAGRAMS:

ENGINE	<u>06-130700</u>	CONTROL PANEL(S)	<u>AM3-986F</u>
--------	------------------	------------------	-----------------

TESTED BY

I. JOHNSON

DATE

24/08/2010