

Generating Set Functional Test Report
In accordance with ISO 8528 - 6 2005

PLANT NUMBER: E9722 CE: No

RATED OUTPUT	KVA	<u>100</u>	RATING CLASSIFICATION	<u>PRP</u>			
	KW	<u>80</u>					
	PHASE	<u>3</u>					
	VOLTS	<u>400/230</u>			PERFORMANCE CLASS	<u>G1</u>	
	AMPS	<u>146</u>					(AS DEFINED BY ISO 8528-1)
	HZ	<u>50</u>					
	RPM	<u>1500</u>					
GOVERNOR TYPE	<u>Electronic</u>		COOLING METHOD	<u>WATERCOOLED</u>			

ENGINE MAKE	<u>Perkins</u>	BUILD NUMBER	<u>R551437</u>
ENGINE MODEL	<u>1104C-44TAG2</u>	SERIAL NUMBER	<u>U507818U</u>
ALTERNATOR MAKE	<u>Mec Alte</u>		
ALTERNATOR MODEL	<u>ECP 34-2S/4</u>	SERIAL NUMBER	<u>A1093277</u>
CONTROL PANEL(S)	<u>None</u>	SERIAL NUMBER(S)	
SWITCHGEAR		SERIAL NUMBER(S)	

LOAD TEST RESULTS (AT UNITY POWER FACTOR)								
LOAD TYPE	LOAD %	HZ	VOLTS	AMPS	KW	ENGINE TEMP	OIL TEMP	OIL PRESS
						DEG C	DEG C	BAR
load acceptance	<u>75%</u>	<u>50.0</u>	<u>400</u>	<u>87</u>	<u>60</u>	<u>—</u>	<u>—</u>	<u>5.0</u>
standby/ prime+10%	<u>110%</u>	<u>50.0</u>	<u>400</u>	<u>127</u>	<u>88</u>	<u>84</u>	<u>—</u>	<u>3.9</u>

GENERATING SET ENCLOSURE MECHANICAL PROTECTION IP

AVERAGE SOUND PRESSURE LEVEL (DBA AT 1 M)

(UNITS WITH ACOUSTIC CANOPIES ONLY & MEASURED UNDER TEST BAY CONDITIONS AT 75% LOAD IN ACCORDANCE WITH ISO8528-10)

AMBIENT TEST CONDITIONS		FUEL/OIL USED	
ALTITUDE (M)	<u>Sea Level</u>	FUEL SPEC	<u>BS2869A2</u>
BAROMETRIC PRESSURE (kpa)	<u>101.1</u>	DENSITY	<u>0.84 kg/l</u>
TEMPERATURE (Deg c)	<u>24</u>	CALORIFIC VALUE	<u>42.5 MJ/kg</u>
HUMIDITY (%)	<u>44</u>	LUB OIL SPEC	<u>Multigrade</u>

WIRING DIAGRAMS:	
ENGINE	<u>06-133000</u> CONTROL PANEL(S) <u> </u>
	<u> </u>

TESTED BY H. D. [Signature]

DATE 09/08/2010