

Generating Set Functional Test Report
In accordance with ISO 8528 - 6 2005

PLANT NUMBER: E9737 CE: NO

RATED OUTPUT	KVA	<u>600</u>	RATING CLASSIFICATION	<u>PnD</u>	
	KW	<u>480</u>			
	PHASE	<u>3</u>			
	VOLTS	<u>400/230</u>		PERFORMANCE CLASS	<u>G1</u>
	AMPS	<u>866</u>		(AS DEFINED BY ISO 8528-1)	
	HZ	<u>50</u>			
	RPM	<u>1500</u>			
GOVERNOR TYPE	<u>B.C.U.</u>	COOLING METHOD	<u>WATERCOOLED</u>		

ENGINE MAKE	<u>PERMINS</u>	BUILD NUMBER	<u>JGAP5099</u>
ENGINE MODEL	<u>2806A-B187M1A</u>	SERIAL NUMBER	<u>U15972U</u>
ALTERNATOR MAKE	<u>WECC-ALTB</u>		
ALTERNATOR MODEL	<u>EC040-1-SL4</u>	SERIAL NUMBER	<u>0001399668</u>
CONTROL PANEL(S)	<u>AUTOSMAN</u>	SERIAL NUMBER(S)	
SWITCHGEAR	<u>—</u>	SERIAL NUMBER(S)	

LOAD TEST RESULTS (AT UNITY POWER FACTOR)

LOAD TYPE	LOAD %	HZ	VOLTS	AMPS	KW	ENGINE TEMP DEG C	OIL TEMP DEG C	OIL PRESS BAR
load acceptance	<u>100</u>	<u>50.0</u>	<u>400</u>	<u>693</u>	<u>480</u>	<u>—</u>	<u>—</u>	<u>5.6</u>
standby/ prime+10%	<u>110%</u>	<u>50.0</u>	<u>400</u>	<u>762</u>	<u>528</u>	<u>90</u>	<u>—</u>	<u>4.0</u>

GENERATING SET ENCLOSURE MECHANICAL PROTECTION IP
 AVERAGE SOUND PRESSURE LEVEL (DBA AT 1 M)
—
 (UNITS WITH ACOUSTIC CANOPIES ONLY & MEASURED UNDER TEST BAY CONDITIONS AT 75% LOAD
 IN ACCORDANCE WITH ISO8528-10)

AMBIENT TEST CONDITIONS		FUEL/OIL USED	
ALTITUDE (M)	<u>Sea Level</u>	FUEL SPEC	<u>BS2869A2</u>
BAROMETRIC PRESSURE (kpa)	<u>101.5</u>	DENSITY	<u>0.84 kg/l</u>
TEMPERATURE (Deg c)	<u>22</u>	CALORIFIC VALUE	<u>42.5 MJ/kg</u>
HUMIDITY (%)	<u>53</u>	LUB OIL SPEC	<u>Multigrade</u>

WIRING DIAGRAMS:

ENGINE		CONTROL PANEL(S)	

TESTED BY

E. JOHNSON

DATE 26/07/2010