

**Generating Set Functional Test Report**  
In accordance with ISO 8528 - 6 2005

PLANT NUMBER: E8776 CE: NO

RATED OUTPUT	KVA	<u>138</u>	RATING CLASSIFICATION	<u>PR10</u>	
	KW	<u>110,4</u>			
	PHASE	<u>3</u>			
	VOLTS	<u>380</u>		PERFORMANCE CLASS	<u>G1</u>
	AMPS	<u>210</u>		(AS DEFINED BY ISO 8528-1)	
	HZ	<u>50</u>			
	RPM	<u>1500</u>			
GOVERNOR TYPE		<u>Electronically</u>	COOLING METHOD	<u>WATERCOOLED</u>	

ENGINE MAKE	<u>PERKINS</u>	BUILD NUMBER	<u>41251440</u>
ENGINE MODEL	<u>1006 TAG</u>	SERIAL NUMBER	<u>0-917418U</u>
ALTERNATOR MAKE	<u>STAMFORD</u>		
ALTERNATOR MODEL	<u>UC1 274E</u>	SERIAL NUMBER	<u>0263526/008</u>
CONTROL PANEL(S)	<u>AUTO-START</u>	SERIAL NUMBER(S)	
SWITCHGEAR		SERIAL NUMBER(S)	

LOAD TEST RESULTS (AT UNITY POWER FACTOR)								
TYPE	LOAD %	HZ	VOLTS	AMPS	KW	ENGINE TEMP DEG C	OIL TEMP DEG C	OIL PRESS BAR
load acceptance	<u>65</u>	<u>50</u>	<u>381</u>	<u>109</u>	<u>71,7</u>	<u>—</u>	<u>—</u>	<u>5,1</u>
standby/prime+10%	<u>110%</u>	<u>50</u>	<u>380</u>	<u>189</u>	<u>121,4</u>	<u>81</u>	<u>—</u>	<u>4,4</u>

GENERATING SET ENCLOSURE MECHANICAL PROTECTION IP  
 AVERAGE SOUND PRESSURE LEVEL (DBA AT 1 M) —  
 (UNITS WITH ACOUSTIC CANOPIES ONLY & MEASURED UNDER TEST BAY CONDITIONS AT 75% LOAD IN ACCORDANCE WITH ISO8528-10)

AMBIENT TEST CONDITIONS		FUEL/OIL USED	
ALTITUDE (M)	<u>Sea Level</u>	FUEL SPEC	<u>BS2869A2</u>
BAROMETRIC PRESSURE (kpa)	<u>1022</u>	DENSITY	<u>0.84 kg/l</u>
TEMPERATURE (Deg c)	<u>11</u>	CALORIFIC VALUE	<u>42.5 MJ/kg</u>
HUMIDITY (%)	<u>82</u>	LUB OIL SPEC	<u>Multigrade</u>

WIRING DIAGRAMS:			
ENGINE	<u>09-160900</u>	CONTROL PANEL(S)	<u>10-173300</u>
			<u>10-170300</u>

TESTED BY: C. Zambelli

DATE: 11/09/2010