

Generating Set Functional Test Report
In accordance with ISO 8528 - 6 2005

PLANT NUMBER: E9808 CE: No

RATED OUTPUT	KVA	<u>80</u>	RATING CLASSIFICATION	<u>PRP</u>	
	KW	<u>64</u>			
	PHASE	<u>3</u>			
	VOLTS	<u>380/220</u>		PERFORMANCE CLASS	<u>G1</u>
	AMPS	<u>122</u>		(AS DEFINED BY ISO 8528-1)	
	HZ	<u>50</u>			
	RPM	<u>1500</u>			
GOVERNOR TYPE	<u>Electronic</u>		COOLING METHOD	<u>WATERCOOLED</u>	

ENGINE MAKE	<u>Perkins</u>	BUILD NUMBER	<u>R551162</u>
ENGINE MODEL	<u>1104 C-44TAG1</u>	SERIAL NUMBER	<u>US124874</u>
ALTERNATOR MAKE	<u>Meca Mte</u>		
ALTERNATOR MODEL	<u>BCP34-1S/4</u>	SERIAL NUMBER	<u>A1098329</u>
CONTROL PANEL(S)	<u>Autostart</u>	SERIAL NUMBER(S)	
SWITCHGEAR		SERIAL NUMBER(S)	

LOAD TEST RESULTS (AT UNITY POWER FACTOR)

LOAD TYPE	LOAD %	HZ	VOLTS	AMPS	KW	ENGINE TEMP DEG C	OIL TEMP DEG C	OIL PRESS BAR
load acceptance	<u>75%</u>	<u>500</u>	<u>380</u>	<u>73</u>	<u>48</u>	<u>-</u>	<u>-</u>	<u>5.6</u>
standby/ prime+10%	<u>110%</u>	<u>500</u>	<u>380</u>	<u>107</u>	<u>70</u>	<u>83</u>	<u>-</u>	<u>4.4</u>

GENERATING SET ENCLOSURE MECHANICAL PROTECTION

IP
75

AVERAGE SOUND PRESSURE LEVEL (DBA AT 1 M)

(UNITS WITH ACOUSTIC CANOPIES ONLY & MEASURED UNDER TEST BAY CONDITIONS AT 75% LOAD IN ACCORDANCE WITH ISO8528-10)

AMBIENT TEST CONDITIONS		FUEL/OIL USED	
ALTITUDE (M)	<u>Sea Level</u>	FUEL SPEC	<u>BS2869A2</u>
BAROMETRIC PRESSURE (kpa)	<u>102.2</u>	DENSITY	<u>0.84 kg/l</u>
TEMPERATURE (Deg c)	<u>11</u>	CALORIFIC VALUE	<u>42.5 MJ/kg</u>
HUMIDITY (%)	<u>94</u>	LUB OIL SPEC	<u>Multigrade</u>

WIRING DIAGRAMS:

ENGINE	<u>06-133000</u>	CONTROL PANEL(S)	<u>10-170300</u>
--------	------------------	------------------	------------------

TESTED BY

H. W. L.

DATE 14/10/2010