

Generating Set Functional Test Report
In accordance with ISO 8528 - 6 2005

PLANT NUMBER: BC9848 CE: NO

RATED OUTPUT	KVA	<u>18</u>	RATING CLASSIFICATION	<u>PDP</u>	
	KW	<u>14.4</u>			
	PHASE	<u>1</u>			
	VOLTS	<u>240</u>		PERFORMANCE CLASS	<u>G1</u>
	AMPS	<u>75</u>		(AS DEFINED BY ISO 8528-1)	
	HZ	<u>50</u>			
	RPM	<u>1500</u>			
GOVERNOR TYPE		<u>MECHANICAL</u>	COOLING METHOD	<u>WATERCOOLED</u>	

ENGINE MAKE	<u>PEDAXINS</u>	BUILD NUMBER	<u>GN65732</u>
ENGINE MODEL	<u>404D-22G</u>	SERIAL NUMBER	<u>U984496T</u>
ALTERNATOR MAKE	<u>WELL-ALTE</u>		
ALTERNATOR MODEL	<u>BC028-VL4</u>	SERIAL NUMBER	<u>0001417515</u>
CONTROL PANEL(S)	<u>MANUAL START</u>	SERIAL NUMBER(S)	
SWITCHGEAR	<u>—</u>	SERIAL NUMBER(S)	

LOAD TEST RESULTS (AT UNITY POWER FACTOR)

LOAD TYPE	LOAD %	HZ	VOLTS	AMPS	KW	ENGINE TEMP DEG C	OIL TEMP DEG C	OIL PRESS BAR
load acceptance	<u>80</u>	<u>50.5</u>	<u>241</u>	<u>48</u>	<u>11.5</u>	<u>—</u>	<u>—</u>	<u>5.1</u>
standby/ prime+10%	<u>110%</u>	<u>50.0</u>	<u>240</u>	<u>66</u>	<u>15.8</u>	<u>84</u>	<u>—</u>	<u>4.4</u>

GENERATING SET ENCLOSURE MECHANICAL PROTECTION

IP
—

AVERAGE SOUND PRESSURE LEVEL (DBA AT 1 M)

(UNITS WITH ACOUSTIC CANOPIES ONLY & MEASURED UNDER TEST BAY CONDITIONS AT 75% LOAD IN ACCORDANCE WITH ISO8528-10)

AMBIENT TEST CONDITIONS		FUEL/OIL USED	
ALTITUDE (M)	<u>Sea Level</u>	FUEL SPEC	<u>BS2869A2</u>
BAROMETRIC PRESSURE (kpa)	<u>100.7</u>	DENSITY	<u>0.84 kg/l</u>
TEMPERATURE (Deg c)	<u>22</u>	CALORIFIC VALUE	<u>42.5 MJ/kg</u>
HUMIDITY (%)	<u>38</u>	LUB OIL SPEC	<u>Multigrade</u>

WIRING DIAGRAMS:

ENGINE		CONTROL PANEL(S)	

TESTED BY

E. JOHNSON

DATE

10/08/2010