

**Generating Set Functional Test Report**  
In accordance with ISO 8528 - 6 2005

PLANT NUMBER: EG9908 CE: NO

RATED OUTPUT	KVA	<u>300</u>	RATING CLASSIFICATION	<u>PDP</u>	
	KW	<u>240</u>			
	PHASE	<u>3</u>			
	VOLTS	<u>400/230</u>		PERFORMANCE CLASS	<u>G1</u>
	AMPS	<u>433</u>		(AS DEFINED BY ISO 8528-1)	
	HZ	<u>50</u>			
	RPM	<u>1500</u>			
GOVERNOR TYPE		<u>B.C.U.</u>	COOLING METHOD	<u>WATERCOOLED</u>	

ENGINE MAKE	<u>VOLVO</u>	BUILD NUMBER	<u>869273</u>
ENGINE MODEL	<u>TAD961GE</u>	SERIAL NUMBER	<u>7009179510</u>
ALTERNATOR MAKE	<u>WISCC-ALTE</u>		
ALTERNATOR MODEL	<u>EC038-2LN/4</u>	SERIAL NUMBER	<u>0001447511</u>
CONTROL PANEL(S)	<u>MANUAL START</u>	SERIAL NUMBER(S)	
SWITCHGEAR	<u>-</u>	SERIAL NUMBER(S)	

**LOAD TEST RESULTS (AT UNITY POWER FACTOR)**

LOAD TYPE	LOAD %	HZ	VOLTS	AMPS	KW	ENGINE TEMP DEG C	OIL TEMP DEG C	OIL PRESS BAR
load acceptance	<u>60</u>	<u>50.0</u>	<u>400</u>	<u>208</u>	<u>144</u>	<u>-</u>	<u>-</u>	<u>7.1</u>
standby/ prime+10%	<u>110%</u>	<u>50.0</u>	<u>400</u>	<u>381</u>	<u>264</u>		<u>-</u>	

GENERATING SET ENCLOSURE MECHANICAL PROTECTION

IP

AVERAGE SOUND PRESSURE LEVEL (DBA AT 1 M)

-

(UNITS WITH ACOUSTIC CANOPIES ONLY & MEASURED UNDER TEST BAY CONDITIONS AT 75% LOAD IN ACCORDANCE WITH ISO8528-10)

AMBIENT TEST CONDITIONS		FUEL/OIL USED	
ALTITUDE (M)	<u>Sea Level</u>	FUEL SPEC	<u>BS2869A2</u>
BAROMETRIC PRESSURE (kpa)	<u>101.6</u>	DENSITY	<u>0.84 kg/l</u>
TEMPERATURE (Deg c)	<u>9</u>	CALORIFIC VALUE	<u>42.5 MJ/kg</u>
HUMIDITY (%)	<u>93</u>	LUB OIL SPEC	<u>Multigrade</u>

**WIRING DIAGRAMS:**

ENGINE	<u>EMSR</u>	CONTROL PANEL(S)	<u>10-170400</u>
--------	-------------	------------------	------------------

TESTED BY

I. JOHNSON

DATE

18/10/2010