

Generating Set Functional Test Report
In accordance with ISO 8528 - 6 2005

PLANT NUMBER: E9918/1 CE: No

RATED OUTPUT	KVA	<u>150</u>	RATING CLASSIFICATION	<u>PRP</u>			
	KW	<u>120</u>					
	PHASE	<u>3</u>					
	VOLTS	<u>380/220</u>			PERFORMANCE CLASS	<u>G1</u>	
	AMPS	<u>228</u>					(AS DEFINED BY ISO 8528-1)
	HZ	<u>50</u>					
	RPM	<u>1500</u>					
GOVERNOR TYPE	<u>Electronic</u>	COOLING METHOD	<u>WATERCOOLED</u>				

ENGINE MAKE	<u>Perkins</u>	BUILD NUMBER	<u>YDS1441</u>
ENGINE MODEL	<u>1006TAG2</u>	SERIAL NUMBER	<u>U918425U</u>
ALTERNATOR MAKE	<u>Stamferd</u>		
ALTERNATOR MODEL	<u>UCI274F</u>	SERIAL NUMBER	<u>0269535/020</u>
CONTROL PANEL(S)	<u>Manual start</u>	SERIAL NUMBER(S)	
SWITCHGEAR		SERIAL NUMBER(S)	

LOAD TEST RESULTS (AT UNITY POWER FACTOR)

LOAD TYPE	LOAD %	HZ	VOLTS	AMPS	KW	ENGINE TEMP DEG C	OIL TEMP DEG C	OIL PRESS BAR
load acceptance	<u>50%</u>	<u>50.0</u>	<u>380</u>	<u>91</u>	<u>60</u>	<u>-</u>	<u>-</u>	<u>4.8</u>
standby/ prime+10%	<u>110%</u>	<u>50.0</u>	<u>380</u>	<u>201</u>	<u>132</u>	<u>82</u>	<u>-</u>	<u>4.0</u>

GENERATING SET ENCLOSURE MECHANICAL PROTECTION IP

AVERAGE SOUND PRESSURE LEVEL (DBA AT 1 M)

(UNITS WITH ACOUSTIC CANOPIES ONLY & MEASURED UNDER TEST BAY CONDITIONS AT 75% LOAD IN ACCORDANCE WITH ISO8528-10)

AMBIENT TEST CONDITIONS		FUEL/OIL USED	
ALTITUDE (M)	<u>Sea Level</u>	FUEL SPEC	<u>BS2869A2</u>
BAROMETRIC PRESSURE (kpa)	<u>101.3</u>	DENSITY	<u>0.84 kg/l</u>
TEMPERATURE (Deg c)	<u>14</u>	CALORIFIC VALUE	<u>42.5 MJ/kg</u>
HUMIDITY (%)	<u>94</u>	LUB OIL SPEC	<u>Multigrade</u>

WIRING DIAGRAMS:

ENGINE	<u>09-160900</u>	CONTROL PANEL(S)	<u>10-170800</u>
--------	------------------	------------------	------------------

TESTED BY H. Wall

DATE 27/09/2010

Generating Set Functional Test Report
In accordance with ISO 8528 - 6 2005

PLANT NUMBER: E9918/2 CE: No

RATED OUTPUT	KVA	<u>150</u>	RATING CLASSIFICATION	<u>PRP</u>			
	KW	<u>120</u>					
	PHASE	<u>3</u>					
	VOLTS	<u>380/220</u>			PERFORMANCE CLASS	<u>G1</u>	
	AMPS	<u>228</u>					(AS DEFINED BY ISO 8528-1)
	HZ	<u>50</u>					
	RPM	<u>1500</u>					
GOVERNOR TYPE	<u>Electronic</u>	COOLING METHOD	<u>WATERCOOLED</u>				

ENGINE MAKE	<u>Perkins</u>	BUILD NUMBER	<u>YDS7441</u>
ENGINE MODEL	<u>1006TAG2</u>	SERIAL NUMBER	<u>UA182804</u>
ALTERNATOR MAKE	<u>Stamferd</u>		
ALTERNATOR MODEL	<u>UCI274F</u>	SERIAL NUMBER	<u>0269535/024</u>
CONTROL PANEL(S)	<u>Manual start</u>	SERIAL NUMBER(S)	
SWITCHGEAR		SERIAL NUMBER(S)	

LOAD TEST RESULTS (AT UNITY POWER FACTOR)								
LOAD TYPE	LOAD %	HZ	VOLTS	AMPS	KW	ENGINE TEMP DEG C	OIL TEMP DEG C	OIL PRESS BAR
load acceptance	<u>50%</u>	<u>50.0</u>	<u>380</u>	<u>91</u>	<u>60</u>	<u>-</u>	<u>-</u>	<u>4.8</u>
standby/ prime+10%	<u>110%</u>	<u>50.0</u>	<u>380</u>	<u>201</u>	<u>132</u>	<u>83</u>	<u>-</u>	<u>4.2</u>

GENERATING SET ENCLOSURE MECHANICAL PROTECTION IP

AVERAGE SOUND PRESSURE LEVEL (DBA AT 1 M)

(UNITS WITH ACOUSTIC CANOPIES ONLY & MEASURED UNDER TEST BAY CONDITIONS AT 75% LOAD IN ACCORDANCE WITH ISO8528-10)

AMBIENT TEST CONDITIONS		FUEL/OIL USED	
ALTITUDE (M)	<u>Sea Level</u>	FUEL SPEC	<u>BS2869A2</u>
BAROMETRIC PRESSURE (kpa)	<u>101.4</u>	DENSITY	<u>0.84 kg/l</u>
TEMPERATURE (Deg c)	<u>13</u>	CALORIFIC VALUE	<u>42.5 MJ/kg</u>
HUMIDITY (%)	<u>100</u>	LUB OIL SPEC	<u>Multigrade</u>

WIRING DIAGRAMS:			
ENGINE	<u>09-160900</u>	CONTROL PANEL(S)	<u>10-170800</u>

TESTED BY H. Wal

DATE 27/09/2010