

Generating Set Functional Test Report
In accordance with ISO 8528 - 6 2005

PLANT NUMBER: E9919 CE: Yes

RATED OUTPUT	KVA	<u>40</u>	RATING CLASSIFICATION	<u>PRP</u>	
	KW	<u>32</u>			
	PHASE	<u>1</u>			
	VOLTS	<u>220</u>		PERFORMANCE CLASS	<u>G1</u>
	AMPS	<u>182</u>		(AS DEFINED BY ISO 8528-1)	
	HZ	<u>50</u>			
	RPM	<u>1500</u>			
GOVERNOR TYPE	<u>Mechanical</u>		COOLING METHOD	<u>WATERCOOLED</u>	

ENGINE MAKE	<u>Perkins</u>	BUILD NUMBER	<u>DK51435</u>
ENGINE MODEL	<u>1103A - 33TG1</u>	SERIAL NUMBER	<u>U247718U</u>
ALTERNATOR MAKE	<u>Mecc Alte</u>		
ALTERNATOR MODEL	<u>ECO 32-3L/4</u>	SERIAL NUMBER	<u>0001444114</u>
CONTROL PANEL(S)	<u>Autostart</u>	SERIAL NUMBER(S)	
SWITCHGEAR		SERIAL NUMBER(S)	

LOAD TEST RESULTS (AT UNITY POWER FACTOR)								
LOAD TYPE	LOAD %	HZ	VOLTS	AMPS	KW	ENGINE TEMP DEG C	OIL TEMP DEG C	OIL PRESS BAR
load acceptance	<u>90%</u>	<u>50.5</u>	<u>220</u>	<u>131</u>	<u>29</u>	<u>-</u>	<u>-</u>	<u>5.1</u>
standby/ prime+10%	<u>110%</u>	<u>50.0</u>	<u>220</u>	<u>160</u>	<u>35</u>	<u>84</u>	<u>-</u>	<u>4.3</u>

GENERATING SET ENCLOSURE MECHANICAL PROTECTION IP
 AVERAGE SOUND PRESSURE LEVEL (DBA AT 1 M)
 (UNITS WITH ACOUSTIC CANOPIES ONLY & MEASURED UNDER TEST BAY CONDITIONS AT 75% LOAD IN ACCORDANCE WITH ISO8528-10)

AMBIENT TEST CONDITIONS		FUEL/OIL USED	
ALTITUDE (M)	<u>Sea Level</u>	FUEL SPEC	<u>BS2869A2</u>
BAROMETRIC PRESSURE (kpa)	<u>100.9</u>	DENSITY	<u>0.84 kg/l</u>
TEMPERATURE (Deg c)	<u>7</u>	CALORIFIC VALUE	<u>42.5 MJ/kg</u>
HUMIDITY (%)	<u>87</u>	LUB OIL SPEC	<u>Multigrade</u>

WIRING DIAGRAMS:	
ENGINE	CONTROL PANEL(S) <u>10-170700</u>

TESTED BY H. Wal

DATE 19/10/2010