

Generating Set Functional Test Report
In accordance with ISO 8528 - 6 2005

PLANT NUMBER: EQ936 CE: NO

RATED OUTPUT	KVA	<u>500</u>	RATING CLASSIFICATION	<u>PDP</u>			
	KW	<u>400</u>					
	PHASE	<u>3</u>					
	VOLTS	<u>400/230</u>			PERFORMANCE CLASS	<u>G1</u>	
	AMPS	<u>702</u>					(AS DEFINED BY ISO 8528-1)
	HZ	<u>50</u>					
	RPM	<u>1500</u>					
GOVERNOR TYPE	<u>B.C.U.</u>	COOLING METHOD	<u>WATERCOOLED</u>				

ENGINE MAKE	<u>PENKINS</u>	BUILD NUMBER	<u>MGBFS120</u>
ENGINE MODEL	<u>2506A-B15TAG2</u>	SERIAL NUMBER	<u>U18858U</u>
ALTERNATOR MAKE	<u>MECL-ALTB</u>	SERIAL NUMBER	<u>0001423356</u>
ALTERNATOR MODEL	<u>BC040-3S/4</u>		
CONTROL PANEL(S)	<u>AV 00 STANT</u>	SERIAL NUMBER(S)	
SWITCHGEAR	<u>—</u>	SERIAL NUMBER(S)	

LOAD TEST RESULTS (AT UNITY POWER FACTOR)

LOAD TYPE	LOAD %	HZ	VOLTS	AMPS	KW	ENGINE TEMP DEG C	OIL TEMP DEG C	OIL PRESS BAR
load acceptance	<u>60</u>	<u>50.0</u>	<u>400</u>	<u>347</u>	<u>240</u>	<u>—</u>	<u>—</u>	<u>5.4</u>
standby/ prime+10%	<u>110%</u>	<u>50.0</u>	<u>400</u>	<u>635</u>	<u>440</u>	<u>87</u>	<u>—</u>	<u>4.5</u>

GENERATING SET ENCLOSURE MECHANICAL PROTECTION

IP

AVERAGE SOUND PRESSURE LEVEL (DBA AT 1 M)

—

(UNITS WITH ACOUSTIC CANOPIES ONLY & MEASURED UNDER TEST BAY CONDITIONS AT 75% LOAD IN ACCORDANCE WITH ISO8528-10)

AMBIENT TEST CONDITIONS		FUEL/OIL USED	
ALTITUDE (M)	<u>Sea Level</u>	FUEL SPEC	<u>BS2869A2</u>
BAROMETRIC PRESSURE (kpa)	<u>100.0</u>	DENSITY	<u>0.84 kg/l</u>
TEMPERATURE (Deg c)	<u>10</u>	CALORIFIC VALUE	<u>42.5 MJ/kg</u>
HUMIDITY (%)	<u>94</u>	LUB OIL SPEC	<u>Multigrade</u>

WIRING DIAGRAMS:

ENGINE	<u>2000 Diagram</u>	CONTROL PANEL(S)	<u>09-162200</u>
--------	---------------------	------------------	------------------

TESTED BY

I. JOHNSON

DATE

04/10/2010