

Generating Set Functional Test Report
In accordance with ISO 8528 - 6 2005

PLANT NUMBER: E9975/1 CE: No

RATED OUTPUT	KVA	<u>40</u>	RATING CLASSIFICATION	<u>PRP</u>	
	KW	<u>32</u>			
	PHASE	<u>3</u>			
	VOLTS	<u>415/240</u>		PERFORMANCE CLASS	<u>G1</u>
	AMPS	<u>56</u>			
	HZ	<u>50</u>			
	RPM	<u>1500</u>			
GOVERNOR TYPE			<u>Mechanical</u>	COOLING METHOD	<u>WATERCOOLED</u>

ENGINE MAKE	<u>Perkins</u>	BUILD NUMBER	<u>Dk51435</u>
ENGINE MODEL	<u>1103A-33TG1</u>	SERIAL NUMBER	<u>U251405U</u>
ALTERNATOR MAKE	<u>Mecc Alte</u>		
ALTERNATOR MODEL	<u>ECO 32-3S/4</u>	SERIAL NUMBER	<u>0001448967</u>
CONTROL PANEL(S)	<u>Autostat</u>	SERIAL NUMBER(S)	
SWITCHGEAR		SERIAL NUMBER(S)	

LOAD TEST RESULTS (AT UNITY POWER FACTOR)

LOAD TYPE	LOAD %	HZ	VOLTS	AMPS	KW	ENGINE TEMP DEG C	OIL TEMP DEG C	OIL PRESS BAR
load acceptance	<u>100%</u>	<u>50.3</u>	<u>415</u>	<u>45</u>	<u>32</u>	<u>-</u>	<u>-</u>	<u>5.0</u>
standby/ prime+10%	<u>110%</u>	<u>50.0</u>	<u>415</u>	<u>49</u>	<u>35</u>	<u>83</u>	<u>-</u>	<u>4.2</u>

GENERATING SET ENCLOSURE MECHANICAL PROTECTION

IP

AVERAGE SOUND PRESSURE LEVEL (DBA AT 1 M)

(UNITS WITH ACOUSTIC CANOPIES ONLY & MEASURED UNDER TEST BAY CONDITIONS AT 75% LOAD IN ACCORDANCE WITH ISO8528-10)

AMBIENT TEST CONDITIONS		FUEL/OIL USED	
ALTITUDE (M)	<u>Sea Level</u>	FUEL SPEC	<u>BS2869A2</u>
BAROMETRIC PRESSURE (kpa)	<u>101.2</u>	DENSITY	<u>0.84 kg/l</u>
TEMPERATURE (Deg c)	<u>13</u>	CALORIFIC VALUE	<u>42.5 MJ/kg</u>
HUMIDITY (%)	<u>77</u>	LUB OIL SPEC	<u>Multigrade</u>

WIRING DIAGRAMS:

ENGINE	<u>06-130700</u>	CONTROL PANEL(S)	<u>10-170300</u>
--------	------------------	------------------	------------------

TESTED BY

H. Wal

DATE 01/11/2010

Generating Set Functional Test Report
In accordance with ISO 8528 - 6 2005

PLANT NUMBER: E9975/2 CE: No

RATED OUTPUT	KVA	<u>40</u>	RATING CLASSIFICATION	<u>PRP</u>			
	KW	<u>32</u>					
	PHASE	<u>3</u>					
	VOLTS	<u>415/240</u>			PERFORMANCE CLASS	<u>G1</u>	
	AMPS	<u>56</u>					(AS DEFINED BY ISO 8528-1)
	HZ	<u>50</u>					
	RPM	<u>1500</u>					
GOVERNOR TYPE	<u>Mechanical</u>		COOLING METHOD	<u>WATERCOOLED</u>			

ENGINE MAKE	<u>Perkins</u>	BUILD NUMBER	<u>Dk51435</u>
ENGINE MODEL	<u>1103A-33TG1</u>	SERIAL NUMBER	<u>U251329U</u>
ALTERNATOR MAKE	<u>Mecc Alte</u>	SERIAL NUMBER	<u>0001448970</u>
ALTERNATOR MODEL	<u>ECO 32-3S/4</u>	SERIAL NUMBER(S)	
CONTROL PANEL(S)	<u>Autostart</u>	SERIAL NUMBER(S)	
SWITCHGEAR		SERIAL NUMBER(S)	

LOAD TEST RESULTS (AT UNITY POWER FACTOR)

LOAD TYPE	LOAD %	HZ	VOLTS	AMPS	KW	ENGINE TEMP DEG C	OIL TEMP DEG C	OIL PRESS BAR
load acceptance	<u>100%</u>	<u>50.2</u>	<u>415</u>	<u>45</u>	<u>32</u>	<u>-</u>	<u>-</u>	<u>5.0</u>
standby/ prime+10%	<u>110%</u>	<u>50.0</u>	<u>415</u>	<u>49</u>	<u>35</u>	<u>83</u>	<u>-</u>	<u>4.1</u>

GENERATING SET ENCLOSURE MECHANICAL PROTECTION IP
 AVERAGE SOUND PRESSURE LEVEL (DBA AT 1 M)
 (UNITS WITH ACOUSTIC CANOPIES ONLY & MEASURED UNDER TEST BAY CONDITIONS AT 75% LOAD IN ACCORDANCE WITH ISO 8528-10)

AMBIENT TEST CONDITIONS		FUEL/OIL USED	
ALTITUDE (M)	<u>Sea Level</u>	FUEL SPEC	<u>BS2869A2</u>
BAROMETRIC PRESSURE (kpa)	<u>101.2</u>	DENSITY	<u>0.84 kg/l</u>
TEMPERATURE (Deg c)	<u>12</u>	CALORIFIC VALUE	<u>42.5 MJ/kg</u>
HUMIDITY (%)	<u>88</u>	LUB OIL SPEC	<u>Multigrade</u>

WIRING DIAGRAMS:

ENGINE	<u>06-130700</u>	CONTROL PANEL(S)	<u>10-170300</u>
--------	------------------	------------------	------------------

TESTED BY H. Wal

DATE 01/11/2010

Generating Set Functional Test Report
In accordance with ISO 8528 - 6 2005

PLANT NUMBER: E9975/3 CE: No

RATED OUTPUT	KVA	<u>40</u>	RATING CLASSIFICATION	<u>PRP</u>			
	KW	<u>32</u>					
	PHASE	<u>3</u>					
	VOLTS	<u>415/240</u>			PERFORMANCE CLASS	<u>G1</u>	
	AMPS	<u>56</u>					(AS DEFINED BY ISO 8528-1)
	HZ	<u>50</u>					
	RPM	<u>1500</u>					
GOVERNOR TYPE	<u>Mechanical</u>	COOLING METHOD	<u>WATERCOOLED</u>				

ENGINE MAKE	<u>Perkins</u>	BUILD NUMBER	<u>Dk51425</u>
ENGINE MODEL	<u>1103A-33TG1</u>	SERIAL NUMBER	<u>U251324U</u>
ALTERNATOR MAKE	<u>Mecc Alte</u>	SERIAL NUMBER	<u>0001448968</u>
ALTERNATOR MODEL	<u>ECO 32-35/4</u>	SERIAL NUMBER(S)	
CONTROL PANEL(S)	<u>Autostart</u>	SERIAL NUMBER(S)	
SWITCHGEAR		SERIAL NUMBER(S)	

LOAD TEST RESULTS (AT UNITY POWER FACTOR)

LOAD TYPE	LOAD %	HZ	VOLTS	AMPS	KW	ENGINE TEMP DEG C	OIL TEMP DEG C	OIL PRESS BAR
load acceptance	<u>100%</u>	<u>50.4</u>	<u>415</u>	<u>45</u>	<u>32</u>	<u>-</u>	<u>-</u>	<u>5.0</u>
standby/ prime+10%	<u>110%</u>	<u>50.0</u>	<u>415</u>	<u>49</u>	<u>35</u>	<u>82</u>	<u>-</u>	<u>4.2</u>

GENERATING SET ENCLOSURE MECHANICAL PROTECTION IP
 AVERAGE SOUND PRESSURE LEVEL (DBA AT 1 M)
 (UNITS WITH ACOUSTIC CANOPIES ONLY & MEASURED UNDER TEST BAY CONDITIONS AT 75% LOAD IN ACCORDANCE WITH ISO8528-10)

AMBIENT TEST CONDITIONS		FUEL/OIL USED	
ALTITUDE (M)	<u>Sea Level</u>	FUEL SPEC	<u>BS2869A2</u>
BAROMETRIC PRESSURE (kpa)	<u>101.1</u>	DENSITY	<u>0.84 kg/l</u>
TEMPERATURE (Deg c)	<u>11</u>	CALORIFIC VALUE	<u>42.5 MJ/kg</u>
HUMIDITY (%)	<u>88</u>	LUB OIL SPEC	<u>Multigrade</u>

WIRING DIAGRAMS:

ENGINE	<u>06-130700</u>	CONTROL PANEL(S)	<u>10-170300</u>
--------	------------------	------------------	------------------

TESTED BY H. Ward

DATE 01/11/2010